



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA192948

Date of Issue: 12 December 2019

Class Description: Non-Prescribed

Product Description: Surge Protection Device (Type 1+2)

Additional Models	Trade Name	Rating	Description
MCF 75-3+FS	OBO BETTERMANN	Uc (50/60Hz) L-N: 255Vac; Iimp L-N: 25kA; In L-N: 35kA; Up L-N: ≤1.5kV; IL: 125A; T1 T2	Without Neutral & Potential Earth Protection

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 12-12-19 192948/2